

Rhinebeck Central School District  
 Sheldon Tieder  
 45 North Park Rd.,  
 Rhinebeck, NY 12572



**SMITH**  
 ENVIRONMENTAL  
 LABORATORY

4 Scenic Drive  
 Hyde Park, NY 12538  
 845-229-6536  
 NY ELAP ID: 10924

**Rhinebeck Central School District - Chancellor Livingston Elementary School**

Lab Sample ID	Sample Location	Analyte	Result	Units	Flag	Action Limit/ MCL	Sample Date	Analysis Date	Method	Matrix
S011712-01	1-Receiving Hose Bib	Lead	5.67	ug/L		15	9/24/2016 7:20	10/10/2016 17:24	EPA 200.8	Drinking Water
S011712-02	2-Kitchen Sink Steam Kettle	Lead	11.2	ug/L		15	9/24/2016 7:20	10/10/2016 17:26	EPA 200.8	Drinking Water
S011712-03	3- Kitchen Double Sink	Lead	0.87	ug/L		15	9/24/2016 7:20	10/10/2016 17:28	EPA 200.8	Drinking Water
S011712-04	4-Kitchen Single Sink	Lead	<0.50	ug/L		15	9/24/2016 7:20	10/10/2016 17:30	EPA 200.8	Drinking Water
S011712-05	5-Kitchen Hand Sink	Lead	2.51	ug/L		15	9/24/2016 7:20	10/10/2016 17:32	EPA 200.8	Drinking Water
S011712-06	6-Kitchen Women's Room	Lead	6.27	ug/L		15	9/24/2016 7:20	10/10/2016 17:34	EPA 200.8	Drinking Water
S011712-07	7-Kitchen Men's Room	Lead	7.41	ug/L		15	9/24/2016 7:20	10/10/2016 17:37	EPA 200.8	Drinking Water
S011712-08	8-Music Corridor WF	Lead	1.49	ug/L		15	9/24/2016 7:20	10/10/2016 17:39	EPA 200.8	Drinking Water
S011712-09	9-Cafe Left WF	Lead	<0.50	ug/L		15	9/24/2016 7:20	10/10/2016 17:41	EPA 200.8	Drinking Water
S011712-10	10-Cafe Bottle Filler	Lead	<0.50	ug/L		15	9/24/2016 7:20	10/10/2016 17:43	EPA 200.8	Drinking Water
S011712-11	11-Cafe Right WF	Lead	<0.50	ug/L		15	9/24/2016 7:20	10/10/2016 17:53	EPA 200.8	Drinking Water
S011712-12	12-Lobby Left WF	Lead	<0.50	ug/L		15	9/24/2016 7:20	10/10/2016 17:55	EPA 200.8	Drinking Water
S011712-13	13-Lobby Right WF	Lead	<0.50	ug/L		15	9/24/2016 7:20	10/10/2016 17:58	EPA 200.8	Drinking Water
S011712-14	14-Prin. Office Bath	Lead	5.24	ug/L		15	9/24/2016 7:20	10/10/2016 18:00	EPA 200.8	Drinking Water
S011712-15	15-Main Boys Sink 1	Lead	1.96	ug/L		15	9/24/2016 7:20	10/10/2016 18:02	EPA 200.8	Drinking Water
S011712-16	16-Main Boys Sink 2	Lead	2.38	ug/L		15	9/24/2016 7:20	10/10/2016 18:04	EPA 200.8	Drinking Water
S011712-17	17-Main Boys Sink 3	Lead	2.15	ug/L		15	9/24/2016 7:20	10/10/2016 18:06	EPA 200.8	Drinking Water
S011712-18	18-Cust Room #2	Lead	2.89	ug/L		15	9/24/2016 7:20	10/10/2016 18:08	EPA 200.8	Drinking Water
S011712-19	19-Main Girls Sink 1	Lead	1.63	ug/L		15	9/24/2016 7:20	10/10/2016 18:12	EPA 200.8	Drinking Water
S011712-20	20-Main Girls Sink 2	Lead	2.45	ug/L		15	9/24/2016 7:20	10/10/2016 18:14	EPA 200.8	Drinking Water
S011712-21	21-Main Girls Sink 3	Lead	1.96	ug/L		15	9/24/2016 7:20	10/10/2016 18:25	EPA 200.8	Drinking Water
S011712-22	22-Main Girls Sink 4	Lead	3.38	ug/L		15	9/24/2016 7:20	10/10/2016 18:27	EPA 200.8	Drinking Water
S011712-23	23-Art Room Sink 1	Lead	1.51	ug/L		15	9/24/2016 7:20	10/10/2016 18:29	EPA 200.8	Drinking Water
S011712-24	24-Art Room Sink 2	Lead	1.28	ug/L		15	9/24/2016 7:20	10/10/2016 18:31	EPA 200.8	Drinking Water
S011712-25	25-Room #124 Sink	Lead	38.1	ug/L		15	9/24/2016 7:20	10/10/2016 18:33	EPA 200.8	Drinking Water
S011712-26	26-Room #124 WF	Lead	0.84	ug/L		15	9/24/2016 7:20	10/10/2016 18:35	EPA 200.8	Drinking Water
S011712-27	27-Room #102 Sink	Lead	7.38	ug/L		15	9/24/2016 7:20	10/10/2016 18:37	EPA 200.8	Drinking Water
S011712-28	Sample not received									
S011712-29	29-Room #123 Sink	Lead	1.45	ug/L		15	9/24/2016 7:20	10/10/2016 18:40	EPA 200.8	Drinking Water
S011712-30	30-Room #123 WF	Lead	1.07	ug/L		15	9/24/2016 7:20	10/10/2016 18:42	EPA 200.8	Drinking Water

Rhinebeck Central School District  
 Sheldon Tieder  
 45 North Park Rd.,  
 Rhinebeck, NY 12572



**SMITH**  
 ENVIRONMENTAL  
 LABORATORY

4 Scenic Drive  
 Hyde Park, NY 12538  
 845-229-6536  
 NY ELAP ID: 10924

**Rhinebeck Central School District - Chancellor Livingston Elementary School**

Lab Sample ID	Sample Location	Analyte	Result	Units	Flag	Action Limit/ MCL	Sample Date	Analysis Date	Method	Matrix
S011712-31	31-Room #103 Sink	Lead	1.35	ug/L		15	9/24/2016 7:20	10/10/2016 18:44	EPA 200.8	Drinking Water
S011712-32	32-Room #103 WF	Lead	1.06	ug/L		15	9/24/2016 7:20	10/10/2016 18:54	EPA 200.8	Drinking Water
S011712-33	33-Room #122 Sink	Lead	1.15	ug/L		15	9/24/2016 7:20	10/10/2016 18:56	EPA 200.8	Drinking Water
S011712-34	34-Room #122 WF	Lead	2.51	ug/L		15	9/24/2016 7:20	10/10/2016 18:59	EPA 200.8	Drinking Water
S011712-35	35-Room #104 Sink	Lead	1.71	ug/L		15	9/24/2016 7:20	10/10/2016 19:01	EPA 200.8	Drinking Water
S011712-36	36-Room #104 WF	Lead	1.73	ug/L		15	9/24/2016 7:20	10/10/2016 19:05	EPA 200.8	Drinking Water
S011712-37	37-Room #121 Sink	Lead	0.85	ug/L		15	9/24/2016 7:20	10/10/2016 19:07	EPA 200.8	Drinking Water
S011712-38	38-Room #121 WF	Lead	1.81	ug/L		15	9/24/2016 7:20	10/10/2016 19:09	EPA 200.8	Drinking Water
S011712-39	39-Room #105 Sink	Lead	1.53	ug/L		15	9/24/2016 7:20	10/10/2016 19:11	EPA 200.8	Drinking Water
S011712-40	40-Room #105 WF	Lead	1.22	ug/L		15	9/24/2016 7:20	10/10/2016 19:13	EPA 200.8	Drinking Water
S011712-41	42-Room #120 WF	Lead	1.33	ug/L		15	9/24/2016 7:20	10/10/2016 19:15	EPA 200.8	Drinking Water
S011712-42	43-Room #106 Sink	Lead	0.77	ug/L		15	9/24/2016 7:20	10/10/2016 19:26	EPA 200.8	Drinking Water
S011712-43	43-Room #106 Sink	Lead	1.34	ug/L		15	9/24/2016 7:20	10/10/2016 19:28	EPA 200.8	Drinking Water
S011712-44	44-Room #106 WF	Lead	2.87	ug/L		15	9/24/2016 7:20	10/10/2016 19:30	EPA 200.8	Drinking Water
S011712-45	45-Room #119 Sink	Lead	0.98	ug/L		15	9/24/2016 7:20	10/10/2016 19:32	EPA 200.8	Drinking Water
S011712-46	46-Room #119 WF	Lead	1.68	ug/L		15	9/24/2016 7:20	10/10/2016 19:34	EPA 200.8	Drinking Water
S011712-47	47-Room #107 Sink	Lead	1.65	ug/L		15	9/24/2016 7:20	10/10/2016 19:37	EPA 200.8	Drinking Water
S011712-48	Sample not received									
S011712-49	49-Cust Closet #3	Lead	2.89	ug/L		15	9/24/2016 7:20	10/10/2016 19:39	EPA 200.8	Drinking Water
S011712-50	50-Room #114 Bath	Lead	1.92	ug/L		15	9/24/2016 7:20	10/10/2016 19:41	EPA 200.8	Drinking Water
S011712-51	51-Room #114 Sink 1	Lead	3.21	ug/L		15	9/24/2016 7:20	10/10/2016 19:43	EPA 200.8	Drinking Water
S011712-52	52-Room #114 Sink 2	Lead	1.34	ug/L		15	9/24/2016 7:20	10/10/2016 19:45	EPA 200.8	Drinking Water
S011712-53	53-Room #114 Sink 3	Lead	1.52	ug/L		15	9/24/2016 7:20	10/10/2016 19:58	EPA 200.8	Drinking Water
S011712-54	54-Room #113 Bath	Lead	1.20	ug/L		15	9/24/2016 7:20	10/10/2016 20:00	EPA 200.8	Drinking Water
S011712-55	55-Room #112 Bath	Lead	1.55	ug/L		15	9/24/2016 7:20	10/10/2016 20:02	EPA 200.8	Drinking Water
S011712-56	56-Room #111 Bath	Lead	2.44	ug/L		15	9/24/2016 7:20	10/10/2016 20:04	EPA 200.8	Drinking Water
S011712-57	57-Room #111 Kitch	Lead	1.56	ug/L		15	9/24/2016 7:20	10/10/2016 20:06	EPA 200.8	Drinking Water
S011712-58	58-Room #136 Sink	Lead	0.69	ug/L		15	9/24/2016 7:20	10/10/2016 20:08	EPA 200.8	Drinking Water
S011712-59	59-Room #136 Left WF	Lead	<0.50	ug/L		15	9/24/2016 7:20	10/10/2016 20:10	EPA 200.8	Drinking Water
S011712-60	60-Room #136 Right WF	Lead	0.53	ug/L		15	9/24/2016 7:20	10/10/2016 20:13	EPA 200.8	Drinking Water

Rhinebeck Central School District  
 Sheldon Tieder  
 45 North Park Rd.,  
 Rhinebeck, NY 12572



**SMITH**  
 ENVIRONMENTAL  
 LABORATORY

4 Scenic Drive  
 Hyde Park, NY 12538  
 845-229-6536  
 NY ELAP ID: 10924

**Rhinebeck Central School District - Chancellor Livingston Elementary School**

Lab Sample ID	Sample Location	Analyte	Result	Units	Flag	Action Limit/ MCL	Sample Date	Analysis Date	Method	Matrix
S011712-61	61-Room #136 Bath	Lead	4.31	ug/L		15	9/24/2016 7:20	10/10/2016 20:15	EPA 200.8	Drinking Water
S011712-62	62-Room #137 Sink	Lead	<0.50	ug/L		15	9/24/2016 7:20	10/10/2016 20:17	EPA 200.8	Drinking Water
S011712-63	63-Room #137 Mens	Lead	2.83	ug/L		15	9/24/2016 7:20	10/10/2016 20:27	EPA 200.8	Drinking Water
S011712-64	64-Room #137 Womens Left	Lead	18.20	ug/L		15	9/24/2016 7:20	10/13/2016 11:36	EPA 200.8	Drinking Water
S011712-65	65-Room #140 Hose Bib	Lead	342	ug/L		15	9/24/2016 7:20	10/10/2016 20:30	EPA 200.8	Drinking Water
S011712-66	66-K-Wing Mens	Lead	<0.50	ug/L		15	9/24/2016 7:20	10/10/2016 20:32	EPA 200.8	Drinking Water
S011712-67	67-K-Wing Womens	Lead	<0.50	ug/L		15	9/24/2016 7:20	10/10/2016 20:34	EPA 200.8	Drinking Water
S011712-68	68-K-Wing Cust Closet	Lead	4.78	ug/L		15	9/24/2016 7:20	10/10/2016 20:36	EPA 200.8	Drinking Water
S011712-69	69-Room #158 Sink	Lead	<0.50	ug/L		15	9/24/2016 7:20	10/10/2016 20:38	EPA 200.8	Drinking Water
S011712-70	70-Room #158 WF	Lead	<0.50	ug/L		15	9/24/2016 7:20	10/10/2016 20:40	EPA 200.8	Drinking Water
S011712-71	Sample not received									
S011712-72	72-Room #155 Sink	Lead	<0.50	ug/L		15	9/24/2016 7:20	10/10/2016 20:42	EPA 200.8	Drinking Water
S011712-73	73-Room #155 WF	Lead	<0.50	ug/L		15	9/24/2016 7:20	10/10/2016 20:47	EPA 200.8	Drinking Water
S011712-74	74-Room #155 Bath	Lead	<0.50	ug/L		15	9/24/2016 7:20	10/10/2016 20:49	EPA 200.8	Drinking Water
S011712-75	75-Room #156 Sink	Lead	<0.50	ug/L		15	9/24/2016 7:20	10/10/2016 20:59	EPA 200.8	Drinking Water
S011712-76	76-Room #156 WF	Lead	<0.50	ug/L		15	9/24/2016 7:20	10/10/2016 21:01	EPA 200.8	Drinking Water
S011712-77	77-Room #156 Bath	Lead	<0.50	ug/L		15	9/24/2016 7:20	10/10/2016 21:04	EPA 200.8	Drinking Water
S011712-78	78-Room #157 Sink	Lead	<0.50	ug/L		15	9/24/2016 7:20	10/10/2016 21:06	EPA 200.8	Drinking Water
S011712-79	79-Room #157 WF	Lead	<0.50	ug/L		15	9/24/2016 7:20	10/10/2016 21:08	EPA 200.8	Drinking Water
S011712-80	80-Room #157 Bath	Lead	<0.50	ug/L		15	9/24/2016 7:20	10/10/2016 21:10	EPA 200.8	Drinking Water
S011713-01	81-2nd Floor Boys Sink 1	Lead	0.86	ug/L		15	9/24/2016 7:20	10/10/2016 21:12	EPA 200.8	Drinking Water
S011713-02	82-2nd Floor Boys Sink 2	Lead	0.91	ug/L		15	9/24/2016 7:20	10/10/2016 21:14	EPA 200.8	Drinking Water
S011713-03	83-2nd Floor Boys Sink 3	Lead	<0.50	ug/L		15	9/24/2016 7:20	10/10/2016 21:16	EPA 200.8	Drinking Water
S011713-04	84-2nd Floor Boys Sink 4	Lead	0.90	ug/L		15	9/24/2016 7:20	10/10/2016 21:18	EPA 200.8	Drinking Water
S011713-05	85-2nd Floor Mens Fac Bath	Lead	4.74	ug/L		15	9/24/2016 7:20	10/10/2016 21:29	EPA 200.8	Drinking Water
S011713-06	86-Cust Closet #219	Lead	13.0	ug/L		15	9/24/2016 7:20	10/10/2016 21:31	EPA 200.8	Drinking Water
S011713-07	87-2nd FL Girls Sink 1	Lead	2.54	ug/L		15	9/24/2016 7:20	10/10/2016 21:33	EPA 200.8	Drinking Water
S011713-08	88-2nd FL Girls Sink 2	Lead	9.38	ug/L		15	9/24/2016 7:20	10/10/2016 21:35	EPA 200.8	Drinking Water
S011713-09	89-2nd FL Girls Sink 3	Lead	2.10	ug/L		15	9/24/2016 7:20	10/10/2016 21:40	EPA 200.8	Drinking Water
S011713-10	90-2nd FL Girls Sink 4	Lead	3.45	ug/L		15	9/24/2016 7:20	10/10/2016 21:42	EPA 200.8	Drinking Water

Rhinebeck Central School District  
 Sheldon Tieder  
 45 North Park Rd.,  
 Rhinebeck, NY 12572



**SMITH**  
 ENVIRONMENTAL  
 LABORATORY

4 Scenic Drive  
 Hyde Park, NY 12538  
 845-229-6536  
 NY ELAP ID: 10924

**Rhinebeck Central School District - Chancellor Livingston Elementary School**

Lab Sample ID	Sample Location	Analyte	Result	Units	Flag	Action Limit/ MCL	Sample Date	Analysis Date	Method	Matrix
S011713-11	91-2nd FL Womens Fac	Lead	2.26	ug/L		15	9/24/2016 7:20	10/10/2016 21:44	EPA 200.8	Drinking Water
S011713-12	92-2nd FL East WF	Lead	<0.50	ug/L		15	9/24/2016 7:20	10/10/2016 21:46	EPA 200.8	Drinking Water
S011713-13	93-2nd FL East Bottle Filler	Lead	<0.50	ug/L		15	9/24/2016 7:20	10/10/2016 21:48	EPA 200.8	Drinking Water
S011713-14	94-Room #201 Sink	Lead	0.87	ug/L		15	9/24/2016 7:20	10/10/2016 21:51	EPA 200.8	Drinking Water
S011713-15	95-Room #218 Sink	Lead	1.15	ug/L		15	9/24/2016 7:20	10/10/2016 22:01	EPA 200.8	Drinking Water
S011713-16	96-Room #202 Sink	Lead	1.09	ug/L		15	9/24/2016 7:20	10/10/2016 22:03	EPA 200.8	Drinking Water
S011713-17	97-Room #217 Sink	Lead	1.74	ug/L		15	9/24/2016 7:20	10/10/2016 22:05	EPA 200.8	Drinking Water
S011713-18	98-Room #203 Sink	Lead	0.84	ug/L		15	9/24/2016 7:20	10/10/2016 22:08	EPA 200.8	Drinking Water
S011713-19	99-Room #216 Sink	Lead	0.88	ug/L		15	9/24/2016 7:20	10/10/2016 22:10	EPA 200.8	Drinking Water
S011713-20	100-Room #204 Sink	Lead	2.19	ug/L		15	9/24/2016 7:20	10/10/2016 22:12	EPA 200.8	Drinking Water
S011713-21	101-Room #215 Sink	Lead	1.08	ug/L		15	9/24/2016 7:20	10/10/2016 22:14	EPA 200.8	Drinking Water
S011713-22	102-Room #205 Sink	Lead	1.80	ug/L		15	9/24/2016 7:20	10/10/2016 22:16	EPA 200.8	Drinking Water
S011713-23	103-Room #214 Sink	Lead	1.02	ug/L		15	9/24/2016 7:20	10/10/2016 22:18	EPA 200.8	Drinking Water
S011713-24	104-Room #204 Sink	Lead	2.01	ug/L		15	9/24/2016 7:20	10/10/2016 22:20	EPA 200.8	Drinking Water
S011713-25	105-Room #213 Sink	Lead	0.89	ug/L		15	9/24/2016 7:20	10/10/2016 22:33	EPA 200.8	Drinking Water
S011713-26	106-2nd FL West WF	Lead	<0.50	ug/L		15	9/24/2016 7:20	10/10/2016 22:35	EPA 200.8	Drinking Water
S011713-27	107-2nd FL West Bottle	Lead	<0.50	ug/L		15	9/24/2016 7:20	10/10/2016 22:37	EPA 200.8	Drinking Water
S011713-28	108-Library Sink	Lead	4.46	ug/L		15	9/24/2016 7:20	10/10/2016 22:40	EPA 200.8	Drinking Water
S011713-29	109-Boiler Room Hose Bib	Lead	13.2	ug/L		15	9/24/2016 7:20	10/10/2016 22:42	EPA 200.8	Drinking Water
S011713-30	110-K-Wing Exterior WF	Lead	<0.50	ug/L		15	9/24/2016 7:20	10/10/2016 22:44	EPA 200.8	Drinking Water
S011713-31	111-Hose Bib #1	Lead	4.27	ug/L		15	9/24/2016 7:20	10/10/2016 22:46	EPA 200.8	Drinking Water
S011713-32	112-Hose Bib #2	Lead	4.33	ug/L		15	9/24/2016 7:20	10/10/2016 22:48	EPA 200.8	Drinking Water
S011713-33	113-Hose Bib #3	Lead	32.8	ug/L		15	9/24/2016 7:20	10/10/2016 22:50	EPA 200.8	Drinking Water
S011713-34	Sample not received									
S011713-35	115-Hose Bib #5	Lead	33.4	ug/L		15	9/24/2016 7:20	10/10/2016 22:52	EPA 200.8	Drinking Water
S011713-36	116-Hose Bib #6/WF	Lead	<0.50	ug/L		15	9/24/2016 7:20	10/10/2016 23:03	EPA 200.8	Drinking Water
S011713-37	117-Hose Bib #7	Lead	21.6	ug/L		15	9/24/2016 7:20	10/10/2016 23:05	EPA 200.8	Drinking Water
S011713-38	118-Hose Bib #8	Lead	17.2	ug/L		15	9/24/2016 7:20	10/10/2016 23:07	EPA 200.8	Drinking Water
S011713-39	119-Hose Bib #9	Lead	146	ug/L		15	9/24/2016 7:20	10/10/2016 23:10	EPA 200.8	Drinking Water
S011713-40	120-Hose Bib #10	Lead	24.5	ug/L		15	9/24/2016 7:20	10/13/2016 11:38	EPA 200.8	Drinking Water

Rhinebeck Central School District  
 Sheldon Tieder  
 45 North Park Rd.,  
 Rhinebeck, NY 12572



**SMITH**  
 ENVIRONMENTAL  
 LABORATORY

4 Scenic Drive  
 Hyde Park, NY 12538  
 845-229-6536  
 NY ELAP ID: 10924

**Rhinebeck Central School District - Chancellor Livingston Elementary School**

Lab Sample ID	Sample Location	Analyte	Result	Units	Flag	Action Limit/ MCL	Sample Date	Analysis Date	Method	Matrix
S011713-41	64.1-Room 137 Womens Right	Lead	7.44	ug/L		15	9/24/2016 7:20	10/10/2016 23:12	EPA 200.8	Drinking Water
S011713-42	117.1 Hose Bib 7.1	Lead	27.7	ug/L		15	9/24/2016 7:20	10/10/2016 23:14	EPA 200.8	Drinking Water
S011713-43	104.1-Room #206 Sink	Lead	0.79	ug/L		15	9/24/2016 7:20	10/10/2016 23:16	EPA 200.8	Drinking Water

Lead analysis performed by ELAP #12406

Key: <=Less Than; ug/L= micrograms per liter; MCL=Maximum Contaminant Level

Reviewed by  
 Dorothy DiNobile, Laboratory Director

*Smith Laboratory is approved as an Environmental Testing Laboratory in conformance with the National Environmental Laboratory Accreditation Conference (NELAC) Standards. This test report pertains only to the above items analyzed on this sample as received by the laboratory. Information supplied by the client is assumed to be correct. This report must be reproduced in its entirety.*

Rhinebeck Central School District  
 Sheldon Tieder  
 45 North Park Rd.,  
 Rhinebeck, NY 12572



**SMITH**  
 ENVIRONMENTAL  
 LABORATORY

4 Scenic Drive  
 Hyde Park, NY 12538  
 845-229-6536  
 NY ELAP ID: 10924

**Rhinebeck Central School District - Chancellor Livingston Elementary School**

Lab Sample ID	Sample Location	Analyte	Result	Units	Flag	Action Limit/ MCL	Sample Date	Analysis Date	Method	Matrix
S012118-01	Room #102 W.F.	Lead	13.1	ug/L		15	10/7/2016 7:33	10/18/2016 16:59	EPA 200.8	Drinking Water
S012118-02	Room #158 Bath	Lead	1.95	ug/L		15	10/7/2016 7:44	10/18/2016 17:01	EPA 200.8	Drinking Water

Lead analysis performed by ELAP #12406

Key: <=Less Than; ug/L= micrograms per liter; MCL=Maximum Contaminant Level

Reviewed by \_\_\_\_\_  
 Dorothy DiNobile, Laboratory Director

*Smith Laboratory is approved as an Environmental Testing Laboratory in conformance with the National Environmental Laboratory Accreditation Conference (NELAC) Standards. This test report pertains only to the above items analyzed on this sample as received by the laboratory. Information supplied by the client is assumed to be correct. This report must be reproduced in its entirety.*



Smith Environmental Laboratory  
 4 Scenic Drive  
 Hyde Park, NY 12538  
 845-229-6536

**CERTIFICATE OF ANALYSIS**

**NY ELAP ID: 10924 / NJ: NY032 / PA: 68-05361**

**Report To:** Rhinebeck Central School District  
 45 North Park Road  
 Rhinebeck, NY 12572

**Lab No:** S013695  
**Reported:** 12/19/16  
**PO:**

**Attention:** Christopher Naney

**Project:** Chancellor Livingston Elementary

**Lab ID:** S013695-01  
**Sample ID:** 64-Room #137 Womens Left  
 Field Chlorine (mg/L):

**Date Collected:** 12/02/16 06:55  
**Date Received:** 12/02/16 09:45

**Matrix:** Drinking Water  
**Collected By:** Brian Shaw

**Total Metals**

<u>Analyte</u>	<u>Results</u>	<u>Flag</u>	<u>Units</u>	<u>RDL</u>	<u>MCL</u>	<u>Method</u>	<u>Analyzed</u>	<u>Analyst</u>
Lead	0.003		mg/L	0.001	0.015	EPA 200.9 Rev 2.2	12/13/16 11:44	SS

Smith Environmental Laboratory

*Smith Environmental Laboratory is approved as an environmental testing laboratory in conformance with the National Environmental Laboratory Accreditation Conference (NELAC) Standards. This test report pertains only to the above items analyzed on this sample as received by the laboratory. Information supplied by the client is assumed to be correct. This report must be reproduced in its entirety.*

Nicole Coenen For Dorothy DiNobile, Laboratory Director



Smith Environmental Laboratory  
4 Scenic Drive  
Hyde Park, NY 12538  
845-229-6536

CERTIFICATE OF ANALYSIS

NY ELAP ID: 10924 / NJ: NY032 / PA: 68-05361

Report To: Rhinebeck Central School District  
45 North Park Road  
Rhinebeck, NY 12572  
Attention: Christopher Naney

Lab No: S013695  
Reported: 12/19/16  
PO:

Project: Chancellor Livingston Elementary

**Notes and Definitions**

≥	Greater than or equal to reporting limit
>	Greater than reporting limit
RDL	Reporting Detection Limit
MCL/AL	Maximum Contaminant Level/Action Level
<	Less than reporting limit
≤	Less than or equal to reporting limit
mg/L	Milligrams per Liter
ug/L	Micrograms per Liter
NTU	Nephelometric Units
T.O.N.	Threshold Odor Number at 60 degrees C.
umho/cm	Micromhos per centimeter
MPN	Most Probable Number
CFU	Colony Forming Units
E1	Estimated, the result presented is greater than, ">" the number shown.
SUB	Analysis performed by a subcontract laboratory

Smith Environmental Laboratory

*Smith Environmental Laboratory is approved as an environmental testing laboratory in conformance with the National Environmental Laboratory Accreditation Conference (NELAC) Standards. This test report pertains only to the above items analyzed on this sample as received by the laboratory. Information supplied by the client is assumed to be correct. This report must be reproduced in its entirety.*

Nicole Coenen For Dorothy DiNobile, Laboratory Director



CHAIN OF CUSTODY

**SMITH ENVIRONMENTAL LABORATORY**  
 4 Scenic Drive  
 Hyde Park, NY 12538-1313  
 Phone: 845-229-6536  
 Fax: 845-229-6538

Copy Results to:  
 Local Health Dept.  Yes  No

Turnaround Time: Standard  RUSH  (surcharge applies)  
 Date Report Requested: \_\_\_\_\_

Project/Facility Name: CHANCELLOR LIVINGSTON ELEMENTARY  
 Location: 48 KNOLLWOOD RD, RHINEBECK

Client Name: RHINEBECK CENTRAL SCHOOL DISTRICT  
 Client Phone No: 845-871-5500 X5529  
 Mailing Address: PO BOX 351  
 Email: stieder@rhinebecksd.org

Copy Report To: \_\_\_\_\_  
 PWS Fed ID NO: NY- \_\_\_\_\_

Log In Review: \_\_\_\_\_  
 Amt Due: \_\_\_\_\_  
 Amt Paid: \_\_\_\_\_  
 Print Method: \_\_\_\_\_  
 Receipt No: \_\_\_\_\_

Order ID No.	Sample Identification	Matrix	(Check One)			Treatment Type & Residual	Date & Time Sampled	Analysis Requested	Container & Preservative	Sample Temp. (C)	Meas. Method (MMS)	Meas. Client Pres. (Y/N)
			Grab	Comp # hrs	First Draw							
SO 13485	64-ROOM #137 WOMENS LEFT				<input checked="" type="checkbox"/>		12/21/16 6:55	Pb	250ml pl	20.9	M	M

Sampled By: (Name) **BRIAN SHAW** (Title) **MECHANIC**

I hereby affirm that the information above is true and complete to the best of my knowledge. I acknowledge that Smith Environmental Laboratory (SEL) reserves the right to subcontract testing to a NYS DOH ELAP approved lab which holds required certifications in the event that it is unable to perform the analysis. I agree to allow samples be sent to a sub laboratory at the discretion of SEL. I also affirm that I am responsible for payment at time of receipt, unless other arrangements are approved in advance.

Sample Relinquished By: \_\_\_\_\_ Received By: **BRB** Date: **12/21/16** Time: **9:45**

Sample Relinquished By: \_\_\_\_\_ Received By: \_\_\_\_\_ Date: \_\_\_\_\_ Time: \_\_\_\_\_

Samples(s) received: \_\_\_\_\_  
 In Correct Bottle:  Yes  No

On Ice:  Yes  No Refer to back of chain for tests requiring thermal preservation.

Note: Thermal preservation is not when samples are received. If temperature is greater than 6°C, samples will be considered to meet thermal preservation if received in sufficient ice within 8 hours of collection.

Note: Samples requiring chemical preservation which are received unpreserved will be preserved at the laboratory at the time of receipt.

Comments: \_\_\_\_\_

Data Review: Mgr \_\_\_\_\_ Date \_\_\_\_\_